

- Any waters or wastes containing toxic or poisonous solids, liquids or gases in sufficient quantity, either singly or by interaction with other wastes, to injure or interfere with any sewage treatment process, constitute a hazard to humans or animals, create a public nuisance, or create any hazard in the receiving waters of the sewage treatment plant.
- Any wastewater having a pH less than 6.0 or greater than 9.5 or having any other corrosive property capable of causing damage or hazard to structures, equipment, and/or personnel of the Water Pollution Control Facility.
- Solid or viscous substances in quantities or of such a size greater than one-half inch (1/2") capable of causing obstruction to the flow in sewers or other interference with the proper operation of the sewage works such as, but not limited to, coffee grounds, ashes, cinders, sand, mud, straw, shavings, metal, glass, rags, feathers, tar plastics, wood, unground garbage, whole blood, paunch manure, hair and fleshings, entrails, paper dishes, cups, milk containers, etc., either whole or ground by garbage grinders.
- Any waters or wastes containing strong acid, iron, pickling wastes or concentrated plating solutions whether neutralized or not.

Installation of Public Sewer Service Connection

1. A check payable to the Town of Warren Sewer Department and Certificate of Insurance must be submitted before receiving Sewer Connection Permits.
2. Sewer connections shall only be made within the calendar dates of April 1 through November 1, on Monday through Thursday between 7 AM and 2:30 PM, excluding holidays. Any exceptions must be approved by the Warren Sewer Department Superintendent
3. Applicant or Contractor must notify the Warren Sewer Department at least 24 hours in advance before starting any sewer connection work. (413) 436-5796
wwtp@warren-ma.gov
4. All sewer connections must be inspected by the Warren Sewer Department or Representative. Photo documentation to be taken during construction. Sewer connections may require a Clerk of the Works (fees to be paid by Applicant). Sewer connections that are backfilled without being inspected will have to be uncovered for proper inspection. Connections made without a permit will be subject to penalties as allowed by the Town of Warren Sewer Use Regulations.
5. Contractor is responsible for obtaining trench opening permit and/or other required permits prior to initiating any construction.
6. Sewer connections into manhole structures or force mains are strictly prohibited. Connections of sewer service lines to Town sewers shall be by means of manufactured fittings or wye fittings. Tee wyes will not be allowed. If in making a sewer service connection, a section of sewer pipe is damaged, that section shall be replaced by the Contractor at his or her expense.